

Template for  
Delivery of Comments  
On Proposed Construction Codes of the District of Columbia 2013

List of

Reviewer(s)/Telephone #: David Wilmot, Aon Fire Protection\_\_\_\_  
301-220-1212 / 202-412-0634\_\_\_\_\_

2013 Code Reviewed: 12 DCMR A, IBC - Chap. 14 - Exterior Walls

Date: January 28, 2013\_\_\_\_\_

| Section Reference | Title/Subject                        | Comment                                                                                                                                                                                                                                                              |
|-------------------|--------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| IBC Section 1403  | Vertical and later flame propagation | Deleted Entirely<br><br>NOTE TO DCBIA MEMBERSHIP: While this section was deleted in its entirety, it is anticipated that a public comment may be submitted seeking inclusion of alternatives to NFPA 285 compliance in lieu of complete deletion of the requirement. |